




SECTION D-D WITHOUT PERMEABLE BASE




SECTION D-D WITH PERMEABLE BASE






SECTION A-A



SECTION B-B

SECTION C-C




NOTE:

PRECAST CONCRETE SPLASH PADS MAY BE INSTALLED AS APPROVED BY THE ENGINEER.

TOP OF SPLASH PAD SHALL MATCH EXISTING CROSS SLOPE. CONSTRUCT BEND IN SPLASH PAD WHERE CROSS SLOPE CHANGES.

DIMENSIONS ARE APPROXIMATE AND CAN BE ADJUSTED AS DIRECTED BY THE ENGINEER.

ITEM	2:1	3:1	4:1	6:1
Α	5.48′	6.19′	6.95′	8.58′
В	2.70′	3.07′	3.46′	4.28′
С	0.78′	1.12′	1.49′	2.30′
D	2.00′	2.00′	2.00′	2.00′
E	2.00′	2.00′	2.00′	2.00′
F	0.46′	0.61′	0.78′	1.18′
G	0.71′	1.07′	1.46′	2.27'
Н	2.31′	2.51′	2.71′	3.13′
CONC.	0.15 C.Y.	0.17 C.Y.	0.20 C.Y.	0.25 C.Y.



PAVEMENT UNDERDRAINAGE
CROSS DRAINS

DATE: _____ EFFECTIVE: 07-01-2006 605.10G 3